


Recommended Splicing: EDRN's on Sides & SWK's on the Bottom



	4" TO 8" W TRAY	12" W TRAY	18" TO 24" W TRAY	30" TO 36" W TRAY
EDRN QTY	x2	x2	x2	x2
SWK QTY	x0	x1	x2	x4

ADD ONE ADDITIONAL SWK ON THE BOTTOM FOR 4", 6", 8", 18", or 30" W TRAY FOR PAINTED TRAY OVER COPPER BONDING STRIP TO MAINTAIN ELECTRICAL CONTINUITY

"Copyright LNA, Inc. Drawings are proprietary and may not be copied or otherwise duplicated or used without express written permission."

Legrand 8319 State Rt. 4 Mascoutah, IL 62258 USA 800-658-4641 618-566-3250 Fax618-566-4978 www.legrand.us/cablofil